



City of Austin

Legislation Details (With Text)

File #:	22-1018	Status:	Agenda Ready
Type:	Consent	In control:	City Council
File created:	12/20/2021	Final action:	1/27/2022
On agenda:	1/27/2022		
Title:	Authorize negotiation and execution of all documents and instruments necessary or desirable to acquire a permanent Electric Transmission and Distribution Easement consisting of approximately 0.114 acre (4,958 square feet), out of the North Lamar Park Annex, a subdivision in Travis County, Texas, and being a portion of the property located at 9307 N. Lamar Blvd., Austin, Texas 78753, for the Austin Energy Transmission Circuit 811 JL-MC 138kV upgrade project, in an amount not to exceed \$323,243, including standard and customary closing costs and fees.		
Sponsors:			
Indexes:	District 2		
Code sections:			
Attachments:	1. Map, 2. Recommendation for Action		

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Posting Language

Authorize negotiation and execution of all documents and instruments necessary or desirable to acquire a permanent Electric Transmission and Distribution Easement consisting of approximately 0.114 acre (4,958 square feet), out of the North Lamar Park Annex, a subdivision in Travis County, Texas, and being a portion of the property located at 9307 N. Lamar Blvd., Austin, Texas 78753, for the Austin Energy Transmission Circuit 811 JL-MC 138kV upgrade project, in an amount not to exceed \$323,243, including standard and customary closing costs and fees.

Lead Department

Austin Energy.

Fiscal Note

Funding in the amount of \$323,243 is available in the Fiscal Year 2021-2022 Capital Budget of Austin Energy.

For More Information:

Jeff Vice, Director, Local Government Issues (512) 322-6087; Thomas Pierpoint, VP Electric Service Delivery, (512) 972-9507; Pamela England, Manager, Public Involvement & Real Estate Services, (512) 322-6442.

Council Committee, Boards and Commission Action:

January 10, 2022- The Electric Utility Commission meeting was cancelled due to lack of quorum.

Additional Backup Information:

The project includes an upgrade of the 4.0 mile transmission line with bundled 795 ACSS Drake conductor rated for 3000 amps, and to reinsulate the line and make-ready for ultimate operation at 138kV. The project will provide redundancy and increase reliability. The downtown service area could be seriously jeopardized if one of Austin Energy's four autotransformers fails and is unavailable for an extended period of time while a replacement unit is being secured. In that scenario CKT811 loads could reach 151 percent of its 120 MVA

thermal limit risking outages and fluctuating service. Additional easement widths are necessary for safety and clearance requirements pursuant to the National Electric Safety Code, and for access and maintenance. The property owner of the proposed 4,958sq. ft. permanent easement has accepted the appraised value as compensation.

Strategic Outcome(s):

Government That Works for All.